



NOTES:

MINIMUM COVER
 WASTEWATER SEWER 1.5m
 STORM SEWER 1.5m
 WATERMAIN 1.7m

PAVEMENT STRUCTURE
 HL-3 40mm
 HL-6 50mm
 GRANULAR 'A' 150mm
 GRANULAR 'B' 300mm

SLOPE WITHIN BOULEVARD
 2.0% MIN.
 5.0% MAX.

TELECOM PEDESTALS & GLB's
 MAY BE LOCATED 0.50m FROM
 PROPERTY LINE ON EITHER
 SIDE OF ROAD ALLOWANCE



PUBLIC WORKS & ENGINEERING DEPT.
 ENGINEERING SERVICES DIVISION
 OWEN SOUND ONTARIO

Title
**8.50m LOCAL ROADWAY
 WITH CURB AND GUTTER
 18.0m ROAD ALLOWANCE
 HIGH DENSITY**

1		FIRST ISSUE	2022-06	DMG
No.	DESCRIPTION		DATE	BY
REVISIONS				
DSN:	COS	METRIC		
CHK:	COS	SCALE: N.T.S.		
DRN:	COS	DATE: 2021-04		

FILE No.:

-/-

Drawing No.

A OSS-1803